

**Zone 7 Water Agency Delivered Water PFAS Testing Summary Per Monitoring Order #DW 2022-0001-DDW (Effective 2023)**

Year: 2023

Quarter: 1

	Per- and Polyfluoroalkyl substances (PFAS)	CCRD L	NL	RL	RL Exceedance Methodology	Mochol Well 4		MGDP FW		Hopyard Well 9		DWWTP TR		PPWTP TR	
						Quarter	QRAA	Quarter	QRAA	Quarter	QRAA	Quarter	QRAA	Quarter	QRAA
1	11-chloroeicosafluoro-3-oxaundecane-s-ulfonic acid (11CL-PF3OUdS)	5	NA	NA	NA	ND	NA	ND / ND	NA	ND	NA	ND	NA	ND	NA
2	1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2FTS)	5	NA	NA	NA	ND	NA	ND / ND	NA	ND	NA	ND	NA	ND	NA
3	1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2FTS)	3	NA	NA	NA	ND	NA	ND / ND	NA	ND	NA	ND	NA	ND	NA
4	1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2FTS)	5	NA	NA	NA	ND	NA	ND / ND	NA	ND	NA	ND	NA	ND	NA
5	4,8-dioxa-3H-perfluorononanoic acid (ADONA)	3	NA	NA	NA	ND	NA	ND / ND	NA	ND	NA	ND	NA	ND	NA
6	9-chlorohexadecafluoro-3-oxanone-sulfonic acid (9CL-PF3ONS)	2	NA	NA	NA	ND	NA	ND / ND	NA	ND	NA	ND	NA	ND	NA
7	Hexafluoropropylene oxide dimer acid (HFPO-DA)(GenX)	5	NA	NA	NA	ND	NA	ND / ND	NA	ND	NA	ND	NA	ND	NA
8	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	20	NA	NA	NA	ND	NA	ND / ND	NA	ND	NA	ND	NA	ND	NA
9	Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	3	NA	NA	NA	ND	NA	ND / ND	NA	ND	NA	ND	NA	ND	NA
10	Perfluoro-3-methoxypropanoic acid (PFMPA)	4	NA	NA	NA	ND	NA	ND / ND	NA	ND	NA	ND	NA	ND	NA
11	Perfluoro-4-methoxybutanoic acid (PFMBA)	3	NA	NA	NA	ND	NA	ND / ND	NA	ND	NA	ND	NA	ND	NA
12	Perfluorobutanesulfonic acid (PFBS)	3	500	5000	Single Sample	ND	NA	4.6 / ND	NA	ND	NA	ND	NA	ND	NA
13	Perfluorobutanoic acid (PFBA)	5	NA	NA	NA	ND	NA	ND / ND	NA	ND	NA	ND	NA	ND	NA
14	Perfluorodecanoic acid (PFDA)	3	NA	NA	NA	ND	NA	ND / ND	NA	ND	NA	ND	NA	ND	NA
15	Perfluorododecanoic acid (PFDoA)	3	NA	NA	NA	ND	NA	ND / ND	NA	ND	NA	ND	NA	ND	NA
16	Perfluoroheptanesulfonic acid (PFHpS)	3	NA	NA	NA	ND	NA	ND / ND	NA	ND	NA	ND	NA	ND	NA
17	Perfluoroheptanoic acid (PFHpA)	3	NA	NA	NA	ND	NA	ND / ND	NA	ND	NA	ND	NA	ND	NA
18	Perfluorohexanesulfonic acid (PFHxS)	3	3	20	Single Sample	6.8	NA	21 / 8.4	NA	ND	NA	ND	NA	ND	NA
19	Perfluorohexanoic acid (PFHxA)	3	NA	NA	NA	ND	NA	3.7 / ND	NA	ND	NA	ND	NA	ND	NA
20	Perfluorononanoic acid (PFNA)	4	NA	NA	NA	ND	NA	ND / ND	NA	ND	NA	ND	NA	ND	NA
21	Perfluorooctanesulfonic acid (PFOS)	4	6.5	40	QRAA	6.8	ND	18.2	4.5	ND	ND	ND	ND	ND	ND
22	Perfluorooctanoic acid (PFOA)	4	5.1	10	QRAA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
23	Perfluoropentanesulfonic acid (PFPeS)	4	NA	NA	NA	ND	NA	ND / ND	NA	ND	NA	ND	NA	ND	NA
24	Perfluoropentanoic acid (PFPeA)	3	NA	NA	NA	ND	NA	ND / ND	NA	ND	NA	ND	NA	ND	NA
25	Perfluoroundecanoic acid (PFUnA)	2	NA	NA	NA	ND	NA	ND / ND	NA	ND	NA	ND	NA	ND	NA

Notes:

CCRD L = Consumer Confidence Report Detection Level

NL = Notification Level

RL = Response Level

QRAA = Quarterly Running Annual Average

ND = Non-Detect; Value less than CCRDL

NA = Not Applicable

MGDP\_FW = Mocho Groundwater Demineralization Plant Finished Water

DWWTP\_TR = Del Valle Water Treatment Plant Treated Water

PPWTP\_TR = Patterson Pass Water Treatment Plant Treated Water

Revised 04/03/23