

Zone 7 Water Agency - 2023 1st Quarter Detected PFAS Monitoring Results

				Sample Name :	MOCHO 2	MOCHO 3	MOCHO 4	MGDP_FW*	MGDP_FW*	COL 1	COL 2	STONERIDGE	HOP 9	DVWTP_TR	PPWTP_TR
				Sample Date :	2/2/23	2/2/23	2/2/23	2/2/23	2/21/23	1/3/23	1/4/23	1/3/23	1/12/23	1/9/23	1/9/23
PFAS	CCRDL	NL	RL												
PFOS	4	6.5	40	37	67	6.8	27	9.3	63	27	37	ND	ND	ND	
PFOA	4	5.1	10	4.3	5.6	ND	3.3	ND	8.0	5.1	4.8	ND	ND	ND	
PFBS	3	500	5000	6.7	10	2.0	4.6	2.0	11	6.1	6.9	ND	ND	ND	
PFHxS	3	3	20	30	50	6.8	21	8.4	50	20	32	ND	ND	ND	
PFHxA	3	NA	NA	4.1	7	ND	3.7	ND	8.4	5	5.1	ND	ND	1.8	
PFHpA	3	NA	NA	ND	2.6	ND	ND	ND	3.1	2.0	1.7	ND	ND	ND	
PFBA	5	NA	NA	4.9	4.8	ND	ND	ND	5.0	ND	ND	ND	ND	ND	
PFHpS	3	NA	NA	ND	1.9	ND	ND	ND	1.8	ND	ND	ND	ND	ND	
PFPeA	3	NA	NA	2.9	4.4	ND	1.9	ND	5.2	3.5	3.0	ND	ND	1.8	
PFPeS	4	NA	NA	5.3	8.6	ND	3.9	ND	10	4.6	5.6	ND	ND	ND	

NL = Notification Level

RL = Response Level

CCRDL = Consumer Confidence Report Detection Level

NA = Not Applicable

ND = Non-Detect; Value less than Method Reporting Limit

*Resampled on 2/21/23